

Ref. No. 166 / 2022
31.08.2022

Primary Health Centre
Kuttiyattoor

Date : 19.09.2022


SANITARY FITNESS CERTIFICATE

As per the Govt. Notification No. 1054 / 43 / 79 HD dated 27th June 1979 I MANOJ KUMAR P. (HI/IC) health Inspector P.H.C. Kuttiyattoor and Health Officer of Kuttiyattoor Grama panchayath area do hereby certify that the site in R. S. No:..... Building No: T/492, A, B, C Kuttiyattoor Grama Panchayath proposed for GRACIOUS ENGLISH MEDIUM SCHOOL, ETTEYYAR, MAYYIL owned by FAHAD K.P. (MANAGER), GEMS MAYYIL, ETTEYYAR.....has inspected by me and the sanitary arrangements made at present are satisfactory. Hence a Sanitary fitness certificate issued to run the above thing subject to the condition laid down in the order. Any violation of any one of the conditions will automatically invalid this certificate. I recommend to issue the running licence for the purpose.

This certificate is issued only for the above purpose under the ownership of FAHAD K.P. (MANAGER)..... and personal for during an inspection for the under signed on 19.09.2022.....

Place : KUTTIYATTOOR

Date : 19.09.2022



N2
Manoj Kumar P
Health Inspector
PRIMARY HEALTH CENTRE
KUTTIYATTOOR
RD. CHATTUKAPPARA - 670 592

PURE SOLUTIONS ANALYTICAL LABORATORY AND RESEARCH CENTRE

Govt Approval By Kerala State Pollution Control Board "C" Grade

Certificate No:-PCB/CL/RL/82/2014

Vyaparabhavan Building, Bank road, Calicut-1

Ref: No:- PAL30/07/1

ANALYSIS REPORT

Customer Name & Address:-

GRACIOUS ENGLISH MEDIUM SCHOOL
COMPANY STOP, PAVANNURMOTTA

Sample Source:- Bore well
Sample Drawn By:- party
Sample Code:- PAL30/07/1
Receipt Date&Time:- 30/07/2022 01:17 PM
Test Date:- 30/07/2022
Date of Issue :- 04/08/2022

S.No	Substance/Characteristics	Unit	Limit	Method Of Analysis	Result
Physical Analysis					
1	Colour	HAZEN UNIT	1-5	APHA. 2012	NIL
2	Taste & Odour	NTU	Agreeable	APHA. 2012	AGREEABLE
3	Temperature	°C	RT	APHA. 2012	28
4	Turbidity	NTU	1	APHA. 2012	2.1
5	Total Suspended Solids			APHA. 2012	10
6	Electrical Conductivity	m mhos/cm		APHA. 2012	12
7	Total Dissolved Solids	mg/liter	500	APHA. 2012	4.8
Chemical Analysis					
8	pH		6.5-8.5	APHA. 2012	6.92
9	Acidity	mg/liter	0.5-500	APHA. 2012	4
10	Alkalinity (Total)	mg/liter	200	APHA. 2012	4
11	Total Hardness	mg/liter	200	APHA. 2012	NIL
12	Calcium	mg/liter	75	APHA. 2012	NIL
13	Magnesium	mg/liter	30	APHA. 2012	NIL
14	Chloride	mg/liter	250	APHA. 2012	3.998
15	Nitrate	mg/liter	45	APHA. 2012	NIL
16	Iron	mg/liter	0.3	APHA. 2012	0.34
17	Sulphate	mg/liter	200	APHA. 2012	NIL
18	Residual chlorine	mg/liter	0.2	APHA. 2012	NIL
Microbiological Analysis					
19	Total Coliforms	CFU/ml	Absent	APHA. 2012	ABSENT
20	E.coli	CFU/ml	Absent	APHA. 2012	ABSENT



To,
GRACIOUS ENGLISH MEDIUM SCHOOL
COMPANY STOP, PAVANNURMOTTA

SUB:WATER ANALYSIS REPORT WITH REF No: PAL30/07/1

The sample with Ref.No:PAL30/07/1 was received from *GRACIOUS ENGLISH MEDIUM SCHOOL* on 30/07/2022 01:17 PM for water analysis.The analysis are carried as per APHA 2012/IS 3025 Standards.

Result is attached and the Remarks are given below.

REMARKS:-

1.Turbidity, Iron found high.


Chemist


Microbiologist



NOTE:The results refer only to the parameters tested of the samples provided or collected for analysis
Endorsement of products is neither informed nor implies,All the samples are disposed of 7 days after the report due date unless the laboratory has received special request.The particular test report cannot be reproduced except in full,without prior permission of Head_pure solutions Analytical laboratory.